

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	Me	ODEL DATA - FO	OR COMPRESSED	AIR	
1	Manufacturer: FS-	Curtis			
	Model Number: NxV	160-125	Date:		03/03/21
2	X Air-cooled	Water-cooled		Type:	Screw
			#	of Stages:	1
3*	Full Load Operating Pressure		125	psig b	
4	Drive Motor Nominal Rating		200	hp	
5	Drive Motor Nominal Efficiency		96.2	percent	
6	Fan Motor Nominal Rating (if applicable)		6	hp	
7	Fan Motor Nominal Effi	ciency	89.5	percent	
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	218.0		965	22.	
8*	179.0		828		.62
	151.0		702	21.51	
	121.0		565	21.42	
	70.0		333	21.02	
9*	Total Package Input Power at Zero Flow c, d		0.0	kW	
10	Isentropic Efficiency		69.40	%	
11	35.00 30.00 35.00 25.00 25.00 20.00 10.00 0	Note: Graph is only a vis	400 480 560 640 Capacity (ACFM) ual representation of the data in St 5 KW1/1004 in increments if necess	720 800 880 section 8 ary above 35	960 1040

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- ACFM is actual cubic feet per minute at infet conditions.

 The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

 No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.