| | In Ac | ccordance with | COMPRESSOR DATA S Federal Uniform Test Method for | | Air Compressors | |
|--|---|--|--|---|--------------------------------|--------------------|
| | | | Rotary Compressor: Fixed Sp | | | 1 |
| | 1 | | MODEL DATA - FOR COMPRES | SED AIR | | - |
| 1 | Manuf | facturer: | FS-Curtis | | | |
| | Model Number: RS100D-100 | | | Date: | 6/27/2024 | |
| 2 | X Air-cooled Water-cooled | | | Type: | Screw | |
| | | | | # of Stages: | 1 | |
| 3* | Rated Capacity at Full Load Operating Pressure a, e | | | 457.0 | acfm ^{a,e} | |
| 4* | | d Operating Pressu | h | 100 | psig ^b | |
| 5 | Maximu | m Full Flow Opera | ating Pressure ^c | 100 | psig ^c | |
| 6 | | otor Nominal Rati | | 100 | hp | |
| 7 | Drive Motor Nominal Efficiency | | | 95.4 | percent | |
| 8 | Fan Motor Nominal Rating (if applicable) | | | 5 | hp | |
| 9 | Fan Motor Nominal Efficiency | | | 89.5 | percent | |
| 10* | Total Package Input Power at Zero Flow ^e | | | 31.47 | kW ^e | - |
| 11 | Total Pac | ckage Input Power g Pressure ^d | at Rated Capacity and Full Load | 93.73 | kW^d | |
| 12* | Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e | | | 20.51 | kW/100 cfm ^e | |
| 13 | Isentropic Efficiency | | | 64.80 | Percent | |
| Consult Consult Consult Consult Consult Constant | CAGI websi : a. b. c. | te for a list of partici Measured at the discha ISO 1217, Annex C; A The operating pressure for this data sheet. Maximum pressure att maximum pressure att | erformance Verification Program, these items are pants in the third party verification program: arge terminal point of the compressor package in accor CFM is actual cubic feet per minute at inlet conditions e at which the Capacity (Item 3) and Electrical Consum ainable at full flow, usually the unload pressure setting ainable before capacity control begins. May require ad ower at other than reported operating points will vary w | www.cagi.org dance with ption (Item 11) were measure for load/no load control or th ditional power. | d | - |
| Compressed Air & Gas Institute | е. | Tolerance is specified | in ISO 1217, Annex C, as shown in table below: wer" and "energy" are synonymous for purposes of thi | | Specific Energy | No Load / Zero Flo |
| | | | Volume Flow Rate at specified conditions | Volume Flow Rate | Specific Energy Consumption | Power |
| Member | r | $\frac{\text{m}^3 / \text{min}}{1 + 1 + 1 + 1}$ | $\frac{\mathrm{ft}^3 / \mathrm{min}}{\mathrm{P}^3 / \mathrm{min}}$ | % | % | % |
| | | Below 0.5 0.5 to 1.5 | Below 17.6 17.6 to 53 | +/- 7 | +/- 8 | |
| | | 0.5 to 1.5 1.5 to 15 | 53 to 529.7 | +/- 6 +/- 5 | +/- 7 +/- 6 | +/- 10% |

ROT 030.1

Above 15

12/19 Rev . This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

+/- 4

+/- 5

Above 529.7