

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: FS-Curtis		
	Model Number: RS200D-100	Date:	6/27/2024
2	X Air-cooled Water-cooled	Type:	Screw
		# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure a, e	920.0	acfm ^{a,e}
4*	Full Load Operating Pressure b	100	psig b
5	Maximum Full Flow Operating Pressure ^c	100	psig ^c
6	Drive Motor Nominal Rating	200	hp
7	Drive Motor Nominal Efficiency	96.2	percent
8	Fan Motor Nominal Rating (if applicable)	15	hp
9	Fan Motor Nominal Efficiency	91.7	percent
10*	Total Package Input Power at Zero Flow ^e	62.35	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	186.05	kW^d
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure Pressure	20.22	kW/100 cfm ^e
13	Isentropic Efficiency	65.72	Percent

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Volume Flow Rate

No Load / Zero Flow

Power

%

+/- 10%

Specific Energy

Consumption

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the
 maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

Volume Flow Rate

at specified conditions

Member

Compressed Air & Gas Institute

 $\underline{m}^3 / \underline{min}$ ft³ / min % % Below 17.6 +/- 7 Below 0.5 +/- 8 0.5 to 1.5 17.6 to 53 +/- 6 +/- 7 1.5 to 15 53 to 529.7 +/- 5 +/- 6 Above 15 Above 529.7 +/- 4 +/- 5

ROT 030.1

12/19 Rev . This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.