	1	MODEL DATA - FOR COMPRES	SED AIR		_
1	Manufacturer:	FS-Curtis			
	Model Number:	RS300D-100	Date:	6/27/2024	_
2	X Air-cooled	Water-cooled	Type:	Screw	
			# of Stages:	1	
3*	Rated Capacity at Full Lo	ad Operating Pressure <sup>a, e</sup>	1350.0	acfm <sup>a,e</sup>	-
4*	Full Load Operating Press	h	100	psig <sup>b</sup>	-
5	Maximum Full Flow Oper		100	psig <sup>c</sup>	-
6	Drive Motor Nominal Rat		300		-
	Drive Motor Nominal Eff	-		hp	-
7	Fan Motor Nominal Ratin	•	95.4 15	percent	-
8				hp	_
9	Fan Motor Nominal Effici	-		percent	_
10*	Total Package Input Powe	r at Zero Flow	87.58	kW <sup>e</sup>	_
11	Total Package Input Powe Operating Pressure <sup>d</sup>	r at Rated Capacity and Full Load	270.24	$kW^d$	
12*		t Rated Capacity and Full Load Operating	20.02	kW/100 cfm <sup>e</sup>	
13	Isentropic Efficiency		66.39	Percent	
		Performance Verification Program, these items are		dministrator.	_
NOTES	<ul> <li>a. Measured at the discl ISO 1217, Annex C;</li> <li>b. The operating pressur for this data sheet.</li> <li>c. Maximum pressure at maximum pressure at d. Total package input p</li> </ul>	cipants in the third party verification program: harge terminal point of the compressor package in accor ACFM is actual cubic feet per minute at inlet conditions re at which the Capacity (Item 3) and Electrical Consum- tainable at full flow, usually the unload pressure setting tainable before capacity control begins. May require ad hower at other than reported operating points will vary wi- in 100 127. Amerge C. or aberging tables	<ul> <li>b.</li> <li>ption (Item 11) were measured</li> <li>for load/no load control or the</li> <li>ditional power.</li> </ul>		
essed Air & Gas Institute		I in ISO 1217, Annex C, as shown in table below: ower" and "energy" are synonymous for purposes of thi	s document.		
Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero I Power	
Member	<u>m<sup>3</sup> / min</u>	$\frac{ft^3}{min}$	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/ 100/
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%

ROT 030.1

12/19 Rev . This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

+/- 4

+/- 5

Above 529.7

Above 15